



BUILDING SIGNAGE SPECIFICATIONS
(2020 MSFC)

Address

Address number shall be provided. Refer to Savage Fire Department handout on Premises Identification.

FDC Signage

Reflective sign for FDC: Minimum 18" x 12" with engineer-grade reflective sheeting. Red reflective letters on a white reflective background. Refer to the Exterior Signage Detail sheet for mounting location.

Door Labels

Letters shall be of a contrasting color to the background.

Exterior - Labels on exterior doors shall identify the door use and property address. The main wording shall be in 3" letters with secondary wording in 1.5" letters.

Fire Access Address #	Riser Room Address # No Building Access	Stairs Basement thru 4th Roof Access
---------------------------------	--	---

Interior - Labels on interior doors shall identify the door use.

Wording shall be in 1.5" letters. Reduced size letters shall be pre-approved by the Savage Fire Department.

Fire Access	Roof Access	Mechanical Room
Riser Room	Electrical Room	Fire Alarm Panel

NFPA 704 Sign

An NFPA 704 diamond sign shall be provided on all buildings containing reportable quantities of hazardous materials. The minimum sign size shall be 11" x 11". Smaller signs may be approved depending on material quantities and occupancy type.



Blue (Health) 0 - 4
Red (Flammability) 0 - 4
Yellow (Instability) 0 - 4
White (Special Precautions)



CITY OF
SAVAGE
MINNESOTA

SAVAGE FIRE DEPARTMENT
Station 1
14321 O'Connell Road
Savage, MN 55378

 952-224-3470
 952-882-2656
 comments@cityofsavage.com
 cityofsavage.com

Proper information shall be placed in each colored box to represent the most hazardous level chemical located within the building.

